RO Preventive Maintenance Schedule

			January		February		March		April		May		June		July		August		September		October		November		December	
	Comments	Freq.	Schd	Act	Schd	Act	Schd	Act	Schd	Act	Schd	Act	Schd	Act	Schd	Act	Schd	Act	Schd	Act	Schd	Act	Schd	Act	Schd	Act
Item Identification	Year 2009																									
PM1 Clean RO membrane	2% Citric acid	1/year													x											
PM2 Clean drain valves	2% Citric acid	1/year													x											
PM3 Flush drain valves		1/qtr	x						x						x						x					
PM4 Check flow & pressures		1/qtr	x						x						x						x					
PM5 Replace cartridge filters		2 year																								
PM6 Clean 40 μ filter	Clorox	3 year																								
Item Identification	Year 2010																									
PM1 Clean RO membrane	2% Citric acid	1/year													x											
PM2 Clean drain valves	2% Citric acid	1/year													x											
PM3 Flush drain valves		1/qtr	x						x						x						x					
PM4 Check flow & pressures		1/qtr	x						x						x						x					
PM5 Replace cartridge filters		2 year													x											
PM6 Clean 40 μ filter	Clorox	3 year																								
Item Identification	Year 2011																									
PM1 Clean RO membrane	2% Citric acid	1/year													x											
PM2 Clean drain valves	2% Citric acid	1/year													x											
PM3 Flush drain valves		1/qtr	x						x						x						x					
PM4 Check flow & pressures		1/qtr	x						x						x						x					
PM5 Replace cartridge filters		2 year																								
PM6 Clean 40 μ filter	Clorox	3 year													x											