



1. Supply Sensor connected to System Supply Sensor Input on Mixing Valve.
2. 24 VAC power from transformer in Control Panel.
3. Relay on pump (terminals 1 & 2) controlled from End Point Switch in Control Panel.
4. Temperature adjusted by control switch on Mixing Valve.
5. 120 VAC power to pump from outlet.